

INTERNATIONAL ISLAMIC UNIVERSITY CHITTAGONG
Chattogram, Bangladesh.

TENDER SCHEDULE
For
**SUPPLY, SUPERVISION, INSTALLATION &
COMMISSIONING OF 400 KVA GENERATORS**

International Islamic University Chittagong
Kumira , Chattogram.

SCOPE OF WORK

Sub Station #2 Up-gradation Works Procurement of 400 KVA GENERATORS

TERMS & CONDITIONS:

Schedule collection and Submission related terms:

- i. The schedule with specification may be collected from the office the Accounts and Finance Division (ACFD) from 14 July 2025, Monday to 20 July 2025, Sunday during office hour.
- ii. The date of submission will be 20 July 2025, Sunday within 4 PM.
- iii. The Company has to submit their portfolio with CV or Company Profile to the Planning and Development Division before collection of the schedule/ quotation from Accounts and Finance Division (ACFD).
- iv. The price of the quotation/schedule rate is 2,000/- & has to be attached money receipt of the fees of tender schedule during submission to the Tender box of Purchase & Procurement Division (PPD), IIUC.
- v. Tender must be submitted into Tender box at the following address:
Purchase and Procurement Division,
International Islamic University Chittagong,
Kumira, Chattogram-4203, Bangladesh.
- vi. Following documents must be submitted with the tender
 - a. Money receipt of Tender schedule purchase
 - b. Tender schedule (with sign & seal by bidder)
 - c. Technical specification of all items.
 - d. Price quotation.
 - e. Letter of an authorization of representative of tendered

Bidder's compliance related terms:

- vii. The bidder has to visit the substation location/site before submit the quotation.
- viii. The Company must submit the updated trade license, TIN & BIN Certificate as well as Company Profile.
- ix. The Bidder has to sign & seal on all papers of the quotation and submit accordingly.
- x. Quotation must be submitted as per specified brand, origin, model and technical specifications. The entire product shall be of Fuji, Japan/Mitsubishi-Japan/Siemens, Germany, Parking, England or other reputed brand.
- xi. The company must submit the materials import license & delivery slip.
- xii. The company must submit the pre-qualification certificate, Prior works order & valid client list.

Financial Terms and conditions:


- xiii. The average annual turnover of the tendered shall not be less than 50 million BDT within 3 years.
- xiv. The rate is including VAT & AIT and will be deduct from bill as per government law.
- xv. The company has to submit 2.5% earnest money of the quoted rate & will be returned after successful completion of the works.

Handwritten signature
15.07.25

- xvi. The earnest money shall be returned to the bidder without interest after selecting the successful bidder. The earnest money of successful bidder shall be returned after submitting performance bond.
- xvii. 5% Security money will be deducted from bill and return after six (6) month subject to successful performance of the supplied items.
- xviii. Successful bidder shall submit an amount of 5% of quoted value to the authority as performance bond, which shall be released after six month of successful commissioning. The validity of the performance bond shall be up to 1 years from the date of submission.
- xix. The quoted offer shall be valid up to 120 days from the date of submitting offer.
- xx. Mode of payment shall be as follows.
 - a. 10% of quoted amount at the time of work order but a bank guarantee of equivalent amount shall be submitted against this advance payment.
 - b. 10% of quoted amount shall be paid before delivery & after successful inspection at factory.
 - c. 30% of quoted amount shall be paid within one week after arriving of all material at site, subject to the quality & quantity as per specification & certified by Engineer in Charge.
 - d. 50% of quoted amount shall be paid after successful commissioning.

IIUC authority related terms:

- xxi. IIUC authority reserves the right to accept or reject any offer without showing any reasons thereof.
- xxii. Detail information about specified job dealing/contact with Chief Engineer (In-charge), P&DD, IIUC, Kumira, Chattogram.


15.07.2025

Kad Lalay
15.07.25

**SPECIFICATION OF GENERATOR AND RELATED MATERIALS REQUIRED FOR
THE ELECTRICAL SUB-STATION AND DISTRIBUTION SYSTEM OF IIUC**

400 KVA Generators

S/N	Description	Quantity	Rate																				
1.	<p>Supplying & installation of new 400 KVA Diesel Generator set Standby power : 440 KVA/352 KW Prime power : 400 KVA/320 KW Engine Brand: PERKINS/CUMMINS, UK/USA/Italy Alternator Brand: FG Wilson, Stamford, Mecc-alte/Loroysoner UK/USA/France. Control Model: Power wizard 1.1+ Deep-sea UK/USA Parameter : 50HZ,400V, 0.80 PFI, 1500RPM Brand Origin: USA/UK/ Italy.</p> <p>Standard Items: The following items will be supplied with the gen-set as standard:</p> <p>(i). Battery 12v, 29 plate, 200AH =02 pcs (Rahima afroz) (ii). Anti-vibration mountings inbuilt (iii). Flexible Bellows (iv). Battery charger (v). Main Line 3 pole Circuit Breaker (vi). Mounted original main controlling panel (vii). Fuel tank for 10 hours operation (viii). Operational manual & key etc.</p> <p>Output Ratings</p> <table><tr><th>S/N</th><th>Voltage & Frequency</th><th>prime</th><th>Standby</th></tr><tr><td>01</td><td>400v/230v, 50HZ, power Factor .80</td><td>400 KVA/320 kw</td><td>440 KVA/352 Kw</td></tr></table> <p>Dimensions and weight</p> <table><tr><th>S/N</th><th>Length mm, (in)</th><th>Width mm(in)</th><th>Height mm (in)</th><th>Dry, Kg</th><th>Wet, kg</th></tr><tr><td>01</td><td>3800(149.6")</td><td>1131(44.5")</td><td>2156(84.9")</td><td>3195</td><td>3241</td></tr></table> <p>N.B.: The LC copy from the Bank and Generator Manual including all documents has to be submitted during delivery.</p>	S/N	Voltage & Frequency	prime	Standby	01	400v/230v, 50HZ, power Factor .80	400 KVA/320 kw	440 KVA/352 Kw	S/N	Length mm, (in)	Width mm(in)	Height mm (in)	Dry, Kg	Wet, kg	01	3800(149.6")	1131(44.5")	2156(84.9")	3195	3241	01 set	
S/N	Voltage & Frequency	prime	Standby																				
01	400v/230v, 50HZ, power Factor .80	400 KVA/320 kw	440 KVA/352 Kw																				
S/N	Length mm, (in)	Width mm(in)	Height mm (in)	Dry, Kg	Wet, kg																		
01	3800(149.6")	1131(44.5")	2156(84.9")	3195	3241																		
2.	<p>Supplying & installation of Auto Transfer Switch (ATS) 800A Country of Origin: ACB Brand: Fuji, Japan, ABB, Italy.</p>	01 Set																					

Mahmudul Alam 15.07.25

15.07.2025

Mahmudul Alam
Director (In-charge)
Purchase & Procurement Division
International Islamic university Chittagong